

Potential Asbestos Containing Material Inventory
Wildroot Building Site
August 13, 2014

Main Building, Third Floor				
Linear Inventory				
Pipe Diameter	Length (ft)			
1"	24			
2"	46			
Total	70			
Main Building, Second Floor				
Linear Inventory		Pile Inventory		
Pipe Diameter	Length (ft)		Length	Width
3/4"	32	Drying Room	9	3
1"	14			Height
1.5"	96			Volume (cu. ft.)
2"	84			27
3"	124			Total
4"	158			27
10"	148			
Total	656			
East Wing, Fourth Floor (Stairwell)				
Linear Inventory				
Pipe Diameter	Length (ft)			
6"	30			
Total	30			
East Wing, Second Floor				
Linear Inventory		Pile Inventory		
Pipe Diameter	Length (ft)		Length	Width
3/4"	315	Bag Room	8	4
1"	23			Height
1.5"	223	Bag Room	8	4
2"	108			Volume (cu. ft.)
Total	669			64
				64
				Total
				128
East Wing, First Floor*				
Linear Inventory				
Pipe Diameter	Length (ft)			
3"	40			
Total	40			
Boiler Room**				
Area Inventory				
	Length	Width	Sides***	Area (sq. ft.)
Run 1	40	4	3	480
Run 2	24	4	3	288
			Total	768
SUMMARY				
Total Linear Footage			1465	
Total "Pile" Volume (cu. ft.)			155	
Total Area (Boiler Room) (sq. ft)			768	

* Due to obstructions, comprehensive inspection could not be completed. The linear inventory is a best estimate.

** Assessment accounts for material observed and does not account for material that may be contained within the boiler itself.

*** Estimate based on material still adhering to the conduit.

ft - feet, cu. ft. - cubic feet, sq. ft. - square feet